

Certificate of Completion

Duct Sealing Performed For:

Hendricks, BEN

Overall Sealing Results

When we arrived,
 YOUR DUCTS HAD:

419.6 CFM of Leakage, equivalent to a
79.3 Square Inch Hole


This equals 251.8 refrigerators full of air loss every hour.

After we finished,
 YOUR DUCTS HAVE:

41.1 CFM of Leakage, equivalent to a
7.8 Square Inch Hole

This corresponds to a **90.2% Reduction** in
 Duct Leakage.

Note: Duct Leakage results are calculated in Cubic Feet per Minute (CFM) measured at a standard OPERATING PRESSURE of 25 Pa.



Aeroseal Technician	george
Aeroseal Case ID	4170
Date of Seal	12/9/2016
System Description	UPFLOW
Seal Description	upflow
Hardware	HomeSeal

Duct Sealing Performed By:

KY Energy Pro Inc
 421 Wabasso Ave
 Louisville, KY 40209
 Phone: (502) 758-5122